



Certified Water Testing, LLC

(P) 301.663.5323

15009 N. Franklinville Road
Thurmont, MD 21788

Town of Emmitsburg

Reporting Date: September 19, 2022

Date/Time Received:

Samples 1-10: September 08, 2022 at 1015 hours

LEAD AND COPPER ANALYSES

LOCATION DATE/TIME COLLECTED	LEAD RESULTS mg/L	COPPER RESULTS mg/L	PQL	ANALYSIS DATE/TIME	METHOD NUMBER	ANALYST
44 Park Drive - Bathroom Sink, 09/08/2022 @ 0345am	<0.001	0.009	0.002	09/15/2022 1155	EPA 200.8	MAP
60 Second Avenue-Kitchen Sink, 09/08/2022 @ 0430am	<0.001	0.030		09/15/2022 1206		
25 Park Drive - Kitchen Sink, 09/08/2022 @ 0800am	<0.001	0.014		09/15/2022 1209		
13 First Avenue-Kitchen Sink, 09/08/2022 @ 0730am	<0.001	0.018		09/15/2022 1213		
426 E Main Street - Kitchen Sink, 09/08/2022 @ 0420am	<0.001	0.006		09/15/2022 1216		
22 East Main - Bath Sink, 09/08/2022 @ 0730am	<0.001	0.009		09/15/2022 1227		
441 East Lincoln - Kitchen Sink, 09/08/2022 @ 0645am	<0.001	0.025		09/15/2022 1231		
434A E Main Street - Bath Sink, 09/08/2022 @ 0630	<0.001	0.016		09/15/2022 1234		
2 Seton Place - Kitchen Sink, 09/08/2022 @ 0600am	<0.001	0.027		09/15/2022 1238		
17213 Mountain View Rd Kitchen Sink, 09/08/2022 @ 0605am	<0.001	0.016		09/15/2022 1241		

This testing was subcontracted to Enviro-Chem Laboratories, Maryland lab ID#192

Respectfully submitted,

Vanessa Willhide
Certified Water Testing
Laboratory Manager